Technical Service Bulletin:

Acid Cleaning of Water Coil

Models: All Water Source Heat Pumps




Acid Cleaning Procedure

- 1. Mix one gallon of muriatic acid with three gallons of water (25% muratic acid solution) in a five gallon plastic bucket.
- 2. Disconnect the water inlet and outlet hoses from the heat pump.
- Connect hoses as shown in diagram. Note flow is in the opposite direction from regular flow.
- Using a pump that will tolerate 25% muriatic acid, circulate solution through heat pump for 20 to 30 minutes.
- 5. Flush with clean water.
- 6. Reconnect water inlet and outlet hoses to heat pump.



WARNING:

- Use extreme caution when handling muratic acid
- Contact with muriatic acid can result in serious injury
- ▶ Be sure to wear eye protection and protective gloves
- Acid cleaning should ONLY be performed by a trained technician





Bosch Thermotechnology Corp. 50 Wentworth Avenue Londonderry, NH 03053

Tel: 1-866-305-9974 Fax: 1-954-776-5529 www.boschheatingandcooling.com