ENVIRONMENTAL PRODUCT DECLARATION

as per *ISO 14025* and *EN 15804+A2*

Owner of the Declaration	Bosch Thermotechnik GmbH
Publisher	Institut Bauen und Umwelt e.V. (IBU)
Programme holder	Institut Bauen und Umwelt e.V. (IBU)
Declaration number	EPD-BSC-20260390-IBC1-EN
Issue date	18.06.2026
Valid to	17.06.2031

CS8800iAW 11 O-T

Bosch Thermotechnik GmbH

Institut Bauen und Umwelt e.V.

ECO PLATFORM EPD VERIFIED

www.ibu-epd.com | https://epd-online.com



1. General Information

Bosch Thermotechnik GmbH

Programme holder

IBU – Institut Bauen und Umwelt e.V.
Hegelplatz 1
10117 Berlin
Germany

Declaration number

EPD-BSC-20260390-IBC1-EN

This declaration is based on the product category rules:

HVAC Appliances, 18.08.2023
(PCR checked and approved by the SVR)

Issue date

18.06.2026

Valid to

17.06.2031

Dipl.-Ing. Hans Peters
(Chairman of Institut Bauen und Umwelt e.V.)

Dr. Martina Bender
(Managing Director Institut Bauen und Umwelt e.V.)

CS8800iAW 11 O-T

Owner of the declaration

Bosch Thermotechnik GmbH
Sophienstraße 30-32
35576 Wetzlar
Germany

Declared product / declared unit

The declared unit is one heat pump outdoor unit CS8800iAW 11 O-T.

Scope:

This EPD refers to one heat pump outdoor unit CS8800iAW 11 O-T manufactured in Tranås, Sweden at the production facility of Bosch Thermotechnik GmbH to be used in Europe. The reference year of production is 2024.
The owner of the declaration shall be liable for the underlying information and evidence; the IBU shall not be liable with respect to manufacturer information, life cycle assessment data and evidences.

The EPD was created according to the specifications of EN 15804+A2. In the following, the standard will be simplified as *EN 15804*.

Verification

The standard EN 15804 serves as the core PCR
Independent verification of the declaration and data according to ISO 14025:2011
☐ internally ☒ externally

Dr.-Ing. Nikolay Minkov,
(Independent verifier)

2. Product

2.1 Product description/Product definition

The product in scope is one outdoor unit (ODU) CS8800iAW 11 O-T, which is a part of the air-to-water heat pump family Compress 8800iAW which are encased assemblies designed as a unit, using a vapor compression cycle (refrigerant R290 (Propane)) driven by an electric compressor, to provide delivery of heat according to EN 14511-1. The heat pumps turn ambient heat into energy and can be used for both cooling and heating purposes via the building's heating circuit. The heat pump system always consists of an indoor unit (IDU) and ODU connected through a water-based circuit. The accessories needed for the installation are accounted for with the ODU.

The following trade numbers and product codes are to be covered with this EPD:
CS8800iAW 11 O-T (7-738-602-871)

The following ODUs are identical except for the power output and related electrical consumption. The respective information and scenarios are described in sections 3.1 and 4:
CS8800iAW 13 O-T (7-738-602-872)
CS8800iAW 15 O-T (7-738-602-873)

The following accessories are considered in this EPD:
Cable CANbus (8-738-206-184)
INPA long (8-738-214-740)
Uponor wallDuctDWD (7-747-204-777)
ECOFLEX Anschlusspaket (7-738-336-967)
Connect-Key K 40 (7-738-114-013)

For the placing on the market in the European Union/European Free Trade
Association (EU/EFTA) (with the exception of Switzerland) the following legal provisions apply:

ErP 2009/125/EC + (EU) 813/2013
EN 14825:2022
EN 14511:2022
EN 12102:2022

LVD 2014/35/EU
IEC 60335-2-40:2022
IEC 60335-1:2010+A1+A2
EN 62233:2008+AC:2008

PED 2014/68/EU
EN 378-2:2016

EMC 2014/30/EU
EN IEC 55014-1:2021
EN IEC 55014-2:2021
IEC 61000-3-2:2018+A1+A2
IEC 61000-3-3:2013+A1+A2

RoHS 2011/65/EU + (EU)2015/863
EN IEC 63000:2018

The design and operating characteristics of this product comply with the European and supplementary national requirements. The CE marking declares that the product complies with all the applicable EU legislation, which is stipulated by attaching this marking. The complete text of the Declaration of Conformity is available on the Internet: www.bosch-einfach-heizen.de

2.2 Application

The CS8800iAW heat pumps belong to heating, ventilation, and air conditioning (HVAC) appliances. The main function is the supply of domestic hot water and regulating air temperature in heating and cooling mode with a specific Seasonal Coefficient of Performance (SCOP) and Seasonal Energy Efficiency Ration (SEER) according to *DIN EN 14825*. Liquid-to-water heat pumps can provide many times more heat energy by consuming one kWh of electricity. The technical data of the heat pumps are presented in the respective EPD documents.

2.3 Technical Data

The CS8800iAW 11 O-T has the following technical properties:

Technical properties

Name	Value	Unit
Area of application	Supply of domestic hot water and regulating air temperature in heating and cooling mode	
Type of appliance in terms of working fluids (the first fluid identifies the heat source, the second the heat delivery fluid)	Air-to-water	
Number of appliances considered in the EPD	1	pce.
Weight	216.9	kg
Overall dimension (HxWxD)	1115 x 1350 x 540	mm
Power output at A7/W35 nominal	4.64	kW
Seasonal coefficient of performance (SCOP), average climate conditions, LT-system (35°)	5.4	
Type of refrigerant	R290	
Refrigerant charge	1.7	

Performance data of the product according to the harmonised standards, based on provisions for harmonization.

2.4 Delivery status

Each heat pump unit is delivered individually packaged with the following dimensions (HxWxD): 1115 mm x 1350 mm x 540 mm.

2.5 Base materials/Ancillary materials

Base materials

The main constituents of the product and its accessories are indicated as mass percentages.

Name	Value	Unit
Aluminium	4.53	%
Steel	56.94	%
Brass	0.72	%
Copper	7.83	%
EPP component	1.81	%
PC component	1.38	%
Polyester component	1.27	%
Other plastics	5.75	%
Electronics/complex	20.63	%
Others	2.60	%

This product/article/at least one partial article contains substances listed in the *ECHA candidate list* **(date: 23.04.2026)** (according to *REACH Regulation (EC 1907/2006)*) exceeding 0.1 percentage by mass: yes

The SVHC substance concentration is available per component only. A summary of the SVHC substances per appliance and respective CAS number is provided below.

SVHC CS8800iAW 11 O-T, 13 O-T and 15 O-T duty to declare:
1,1'-(Ethane-1,2-diyl)bis *84852-53-9*
Bis(alpha,alpha- dimethylbenzyl)peroxide *80-43-3*
C,C'-azodi(formamide) *123-77-3*
Cd *7440-43-9*
Chromium (VI) Oxide *1333-82-0*
Diboron-trioxide *1303-86-2*
Diimethylmethylene-p,p'- *80-05-7*
Lead *7439-92-1*
Lead-monoxide *1317-36-8*
Lead Titanium Oxide (PbTiO3) *12060-00-3*
Tris(4-nonylphenyl,) phosphite *26523-78-4*

2.6 Manufacture
The heat pump units are manufactured and assembled at the production plant in Tranås, Sweden. Individual parts and materials are sourced from suppliers or manufactured within Bosch plants and assembled to heat pump units. The assembled heat pump units are then tested and packaged with an installation manual for shipment. The accessories are packed and delivered separately. The Bosch Home Comfort production plants are certified according to *ISO 9001:2015* Quality Management System.

2.7 Environment and health during manufacturing
The Bosch Home Comfort production plants are certified according to: *ISO 14001:2015* Environmental Management System and *ISO 45001:2018* Occupational Health and Safety Management

2.8 Product processing/Installation
The product may only be installed, brought into operation, and maintained by trained personnel.
Directions and regulations below must be followed:
- Local provisions and regulations of the electricity supplier and corresponding special rules
- National building regulations
- ***EN 50160*** (Voltage properties in power grids for public distribution)
- ***EN 12828*** (Heating systems in buildings - Design and installation of water-based heating systems)
- ***EN 1717*** (Protection of potable water against pollution in potable water installations)
- ***EN 378*** (Refrigerating systems and heat pumps - Safety and environmental requirements)
- ***EN60335-2-40*** (Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers)

The installation process covered in the EPD includes the assembly of the pre-assembled heat pump unit, set-up of the electrical connection, the filling and venting and the commissioning. Insulation material and stainless steel pipes are needed for the installation and connection of the heat pump unit to the closed heating system of the building.

2.9 Packaging
The packaging consists of wood, cardboard, plastic foil, paper, and minor metal parts. Bosch Home Comfort participates in country-specific recycling processes that ensure optimum recycling. All the packaging materials are environmentally compatible and can be recycled.

2.10 Condition of use
There is no change of use in the material composition over the service life of the product and/or regarding environmentally relevant material inherent properties over the service life of the product. Units are repaired/components are replaced if required. Rebuilds and repairs may only be performed by trained installers. Inspections and maintenance are necessary for ensuring safe and environmentally friendly operation.

2.11 Environment and health during use
The heat pump may only be installed, brought into operation, and maintained by authorised personnel. Information on the rules of technology as well as on workers' safety and environmental production is provided in the installation manual. All instructions from the installation manual must be observed. Failure to comply with instructions may result in material damage and personal injury, including danger to life.

2.12 Reference service life
The RSL is set to 20 years based on the *PCR IBU Part B*.

2.13 Extraordinary effects
Fire
-

Water
-

Mechanical destruction
Measures against mechanical deconstruction are described in the installation manual.

2.14 Re-use phase
Used appliances contain valuable materials that can be recycled. The various assemblies can be easily dismantled. Synthetic materials are marked accordingly. Assemblies can therefore be sorted by composition and passed on for recycling or disposal.

2.15 Disposal
The product must not be disposed of with other waste environmentally sound recycling in accordance with the *EU Directive 2012/19/EU* on waste electrical and electronic equipment, and classified as 20 01 35* according with the Decision 2014/955/EU. Electrical and electronic equipment shall be disposed of through the respective country's return and collection systems.

2.16 Further information
More information is available here: www.bosch-homecomfortgroup.com/en/company/legal-topics/weee/

3. LCA: Calculation rules

3.1 Declared Unit
The declared unit is one outdoor heat pump unit CS8800iAW 11 O-T.

CS8800iAW 11 O-T

Name	Value	Unit
Declared unit 1	1	pce.
Mass reference	216.9	kg/pce
SCOP	5.4	
SEER	5.37	
E"heating"	1775.23	kWh/a
E"cooling"	1035.75	kWh/a


The accessories delivered with the heat pump unit are considered in this EPD as well and have a weight of 40.55 kg. The packaging of the ODU and accessories have a weight of 31.1 kg.

Scenario - CS8800iAW 13 O-T
SCOP: 5.37
SEER: 5.39
P"heat, design": 5.4
P"cool, design": 9.7
E "heating": 2077.54 kWh/a
E "cooling": 1079.78 kWh/a
E "use": 227326.99 MJ

Scenario - CS8800iAW 15 O-T
SCOP: 5.02
SEER: 5.38
P"heat, design": 6.39
P"cool, design": 10.32
E "heating": 2629.83 kWh/a
E "cooling": 1150.93 kWh/a
E "use": 272214.58 MJ

3.2 System boundary

Type of the EPD: cradle to grave.
The EPD includes cradle-to-grave and module D (A+B+C+D) and follows the modular structure according to *EN15804* (option c) according to the *PCR Part A,* and follows additional requirements for construction products considered as Electronic or Electric Equipment .



Module A1-A3: Raw material supply (extraction, processing, and recycled content) for the components the heat pump units comprise. This includes transport from raw material extraction to the supplier and from the supplier to the Bosch plant. Manufacturing processes at the Bosch plant are also covered, considering energy use, required consumables, production waste and its treatment, as well as internal transport.
Module A4: Transport from the Bosch plant to the building sites of all target markets.
Module A5: Installation of the heat pump unit. Manufacturing of installation material purchased by the installers, energy consumption and disposal of packaging are considered in this module.
Module B1: Propane leakage during the use phase.
Module B2: Covers the maintenance as described in the service manual.
Module B3: Covers the replacement of specific components with spare parts in case of errors.
Module B4: No foreseen replacement of major heat pump parts is required during the RSL. The heat pump unit can be repaired at component level in the event of errors. Hence, no impacts arise from replacement.
Module B5: Refurbishment does not take place.
Module B6: Operational energy use.
Module B7: There is no operational water use.
Module C1: No environmental impacts arise from deconstruction or demolition.
Module C2: Transport to the treatment facility.
Module C3: Disassembly to separate large metal parts for material recycling.
Module C4: The materials which are meant to be disposed are either going to be incinerated without energy recovery or landfilled.

For the environmental impact during manufacturing, the use of green electricity was calculated considering the residual electricity mix for the remaining electricity. The proportion of the electricity demand covered by green electricity in the total electricity demand is 100 %.
The GWP-total emissions of the modelled grid mix for A1-A3 manufacturing result in ~0.0058 kg CO_2eq./kWh.

3.3 Estimates and assumptions

For installation, it was assumed no previous heat pump unit was connected to the building; thus, pipes connecting the heat pump unit to the building's heating system were considered with the IDU. The use of insulation tube, energy consumption and disposal of packaging were considered in A5.
Transport data for materials, waste, and heat pump units utilised information on supplier locations, treatment facilities, and internal distribution channels/routes. However, a few assumptions filled gaps. A 300 km road distribution scenario per heat pump unit was adopted for transport from regional distribution centres to the building site, as per *PCR EPDItaly019*.
No special storage conditions are required, so heat pump storage was neglected.

For spare parts replaced during heat pump unit repairs (B3) and packaging waste, a 100 km road distribution scenario (200 km round trip) to the End-of-Life (EoL) treatment facility was applied. Average European recycling shares and substitution factors (*European Commission, 2022*) were used for packaging EoL.

The heat pump unit's transport to the treatment facility was assumed to be 50 km (100 km round trip) and occurs directly. A collection rate of 100 % without any losses due to the shredding of the material is assumed. *PEP ecopassport PSR, 2021* default EoL routes for specific materials were considered for calculations. Thermal recovery of materials was generally assumed to take place in a MSWI facility with 15 % electrical and 35 % heat utilisation. Following *PCR Part A*, with an R1 value for Ew > 0.6, impacts are reported in module C3. Material neither recycled nor incinerated with energy recovery is assumed to be disposed of via incineration without energy recovery or landfill (50/50 distribution).

3.4 Cut-off criteria

Module A1-A3: Material and energy flows accounting for at least 1 % of renewable or non-renewable primary energy or mass were assessed. The total sum of flows not considered per module did not exceed 5 %. Infrastructure expenses (machinery, buildings, etc.) for the entire new system were not

included, assuming their construction and maintenance impacts do not exceed 1 % of total impacts. Heat provision was excluded as it does not directly contribute to product manufacturing. Conversely, electricity for operating the manufacturing infrastructure was considered. Plant production waste, primarily packaging and small metal parts from manufacturing, was subject to a 5 % cut-off criterion to ensure calculation feasibility.

Module C1: Due to the minor electricity consumption during the manual removal (less than 5 %) in C1 compared to all other C modules, the activities related to module C1 were cut off. Hence, no processes are allocated to module C1.

3.5 Background data

The LCA model was developed with the *LCA for Experts* software with the support of the *ecoinvent 3.9.1 database* used for the background datasets.

3.6 Data quality

Product-specific data were collected for all life cycle phases and processes within Bosch HC's sphere of influence. This foreground data, characterised by a high level of detail (detailed bills of materials, direct measurements, waste and energy reports, technical datasheets, service manuals, and expert knowledge), corresponds to 'very good quality' as defined in *EN 15804 Annex E*.

Generic data were used for:
- **Upstream processes:** Extraction and pre-processing of raw materials prior to their arrival at the Bosch plant.
- **Downstream processes:** Utilizing additional technical data according to *EN 15804,* chapter 7.3, and encompassing all life cycle stages (cradle to grave), impacts (and benefits) of waste treatment (incineration, recycling, and substituted processes) were calculated. This calculation used generic data, supplemented by product-specific information on calorific values and/or treatment type.

The background data (*ecoinvent v.3.9.1*) correspond to 'good quality' as defined in *EN 15804 Annex E*. This is because the best available background datasets were selected based on factors like supplier location or energy consumption, and the technology for processing the materials employed was also considered.

3.7 Period under review

The LCA study was developed between March and December 2025, with data referring to the year 2024. The distribution scenario is approximated for the year 2026.

3.8 Geographic Representativeness

Land or region, in which the declared product system is manufactured, used or handled at the end of the product´s lifespan: Europe

3.9 Allocation

There are no co-products generated during the heat pump unit production. Concerning allocations in the foreground system to allocate plant-related activities such as energy consumption, internal transport, and waste production as well as related loads and benefits product- and plant-specific allocation keys are used. The allocation key is used in A1-A3 and module D only.

3.10 Comparability

Basically, a comparison or an evaluation of EPD data is only possible if all the data sets to be compared were created according to *EN 15804* and the building context, respectively the product-specific characteristics of performance, are taken into account. The LCA model was developed based on the support of the *ecoinvent 3.9.1* database used for the background datasets.

4. LCA: Scenarios and additional technical information

Characteristic product properties of biogenic carbon

The total mass of biogenic carbon-containing materials of the heat pump unit is less than 5 % of the total mass of the product. The total mass of biogenic carbon-containing materials in the accompanying packaging is presented in the following table.

Information on describing the biogenic carbon content at factory gate

Name	Value	Unit
Biogenic carbon content in product	-	kg C
Biogenic carbon content in accompanying packaging	23.97	kg C

The disposal of the packaging material on the construction site is declared in A5.

Note: 1 kg of biogenic carbon is equivalent to 44/12 kg of CO_2.

Transport from the gate to the site (A4)

The following information regarding shipping from Bosch plants to regional distribution centres (RDCs) is reported: RDC locations, distances between dispatch points and RDCs, transportation types, and the number of units shipped to RDCs (including the weight of products, accessories, and packaging). The target market weighted average tkm per heat pump unit was calculated based on the respective weight of the heat pump unit including packaging. In line with Science Based Targets initiative (SBTi) reporting, a 70 % capacity utilisation was considered. As no special storage conditions are required, the storage of the heat pumps was neglected.

Assembly (A5)

Name	Value	Unit
Insulation material	2.5	kg
Electricity consumption	0.583	MJ

Disposal of packaging materials occurs in module A5. As End-of-Life (EoL) treatment varies by country, an average European EoL scenario was calculated across all target countries. Average European recycling shares and substitution factors from the EF3.0 method were applied (*European Commission, 2022*).

Repair (B3)

Units are repaired or components replaced as required. This module includes all input materials, components, energy, packaging, and transport associated with replacing heat pump unit components and their End-of-Life (EoL) treatment, based on a basic assumption of 0.3 % spare parts factor.

Name	Value	Unit
Repair cycle	0.003	Number/RSL
Electricity consumption	0.00175	MJ

The RSL is set to 20 years based on the *PCR IBU Part B.*

Reference service life

Name	Value	Unit
Reference service life	20	a

Operational energy use (B6)

The CS8800iAW 11 O-T, 13 O-T and 15 O-T differ in terms of operational energy use.

Name	Value	Unit
Electricity consumption - 11 O-T	56219,68	kWh
Electricity consumption - 13 O-T	63146.39	kWh
Electricity consumption - 15 O-T	75615.16	kWh

Operational energy use (B6) and Operational water use (B7)

The heat pump system always consists of IDU and ODU. To avoid double-counting, the operational energy use is accounted for in relation to the ODU.

End of life (C1-C4)

Module C1: No impacts on site as disassembly occurs at the treatment facility.
Module C2: To account for the transportation of the heat pumps, accessories, and installation material to the EoL treatment facility, a 100 km road distribution scenario was applied (assuming 50 km outward and 50 km return journey).
Module C3: After disassembling the cover panels, the remaining heat pump units and accessories are shredded in an electronic waste shredding process. Metals and plastics are then either recycled or incinerated with energy recovery
Module C4: Material that is neither recycled nor incinerated with energy recovery is assumed to be disposed of either by incineration without energy recovery or in a landfill.

Name	Value	Unit
Recycling	138.8	kg
Energy recovery	22.996	kg
Disposal	111.077	kg

Reuse, recovery and/or recycling potentials (D), relevant scenario information

This module covers burdens from recycling processes and net credits from energy or material substitution. These burdens and credits arise from the recycling, substitution, or thermal recovery of: production plant waste, packaging of heat pump systems and accessories, repair activity waste, and End-of-Life (EoL) heat pump systems and installation material. In general, thermal recovery of materials was assumed to take place in a MSWI facility with 15 % electrical and 35 % heat utilisation. The exported energy substitutes fossil fuels. It is assumed that thermal energy is generated from natural gas and substituted electricity corresponds to the European electricity mix. Specifically, the generated energy is assumed to replace impacts from the following *ecoinvent database v.3.9.1* datasets (Europe without Switzerland): 'market for heat, district or industrial, natural gas' and 'market group for electricity, high voltage'. Recycled materials are assumed to substitute functionally equivalent primary materials. The share of secondary material (according to ecoinvent 3.9.1 system model *EN 15804*, inventory indicator *ISO 21930* use of secondary material) and material substitution were accounted for. Average European substitution factors were applied (*European Commission, 2022*).

5. LCA: Results

The LCA results are presented below.

DESCRIPTION OF THE SYSTEM BOUNDARY (X = INCLUDED IN LCA; MND = MODULE OR INDICATOR NOT DECLARED; MNR = MODULE NOT RELEVANT)

Product stage			Construction process stage		Use stage							End of life stage				Benefits and loads beyond the system boundaries
Raw material supply	Transport	Manufacturing	Transport from the gate to the site	Assembly	Use	Maintenance	Repair	Replacement	Refurbishment	Operational energy use	Operational water use	De-construction demolition	Transport	Waste processing	Disposal	Reuse-Recovery-Recycling-potential
A1	A2	A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X

RESULTS OF THE LCA - ENVIRONMENTAL IMPACT according to EN 15804+A2: 1 pce CS8800iAW 11 O-T

Parameter	Unit	A1-A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
GWP-total	kg CO_2 eq	1.51E+03	9.63E+01	1.61E+01	2.68E-03	0	7.42E-01	0	0	2.04E+04	0	0	3.87E+00	4.37E+01	1.07E+02	-2.49E+02
GWP-fossil	kg CO_2 eq	1.5E+03	9.62E+01	1.38E+01	2.68E-03	0	7.4E-01	0	0	2.02E+04	0	0	3.87E+00	4.17E+01	7.93E+01	-2.48E+02
GWP-biogenic	kg CO_2 eq	8.8E+00	2.8E-02	2.28E+00	0	0	2E-03	0	0	1E+02	0	0	1.13E-03	2.05E+00	2.76E+01	-7.05E-02
GWP-luluc	kg CO_2 eq	4E+00	4.78E-02	1.48E-02	0	0	6.72E-04	0	0	5.05E+01	0	0	1.91E-03	2.74E-02	1.58E-02	-2.63E-01
ODP	kg CFC11 eq	7.26E-05	2.09E-06	4.84E-07	0	0	2.11E-08	0	0	3.84E-04	0	0	8.42E-08	2.06E-07	4.36E-06	-5.07E-06
AP	mol H^+ eq	7.22E+00	1.82E-01	3.04E-02	0	0	3.29E-03	0	0	3.38E+01	0	0	6.82E-03	6.02E-02	5.4E-02	-8.94E-01
EP-freshwater	kg P eq	1.82E+00	6.81E-03	3.69E-03	0	0	3.05E-04	0	0	1.91E+01	0	0	2.75E-04	7.13E-03	2.01E-02	-1.8E-01
EP-marine	kg N eq	2.52E+00	5.97E-02	1.92E-02	0	0	1.31E-03	0	0	1.89E+01	0	0	2.15E-03	2.82E-02	5.92E-02	-2.75E-01
EP-terrestrial	mol N eq	2.8E+01	6.09E-01	1.4E-01	0	0	8.28E-03	0	0	1.69E+02	0	0	2.17E-02	2.88E-01	2.29E-01	-3.04E+00
POCP	kg NMVOC eq	9.37E+00	3.44E-01	6.72E-02	3.98E-02	0	3.45E-03	0	0	5.45E+01	0	0	1.31E-02	7.27E-02	9.55E-02	-1.29E+00
ADPE	kg Sb eq	2.98E-01	3.13E-04	1.18E-04	0	0	3.36E-05	0	0	2.41E-01	0	0	1.26E-05	1.97E-04	8.22E-05	-1.89E-02
ADPF	MJ	2.09E+04	1.35E+03	2.89E+02	0	0	1.11E+01	0	0	2.82E+05	0	0	5.43E+01	2.11E+02	3.15E+02	-3.44E+03
WDP	m^3 world eq deprived	1.06E+03	8.41E+00	5.87E+00	0	0	5.85E-01	0	0	1.55E+04	0	0	3.4E-01	5.1E+00	9.31E+00	-1.08E+02

GWP = Global warming potential; ODP = Depletion potential of the stratospheric ozone layer; AP = Acidification potential of land and water; EP = Eutrophication potential; POCP = Formation potential of tropospheric ozone photochemical oxidants; ADPE = Abiotic depletion potential for non-fossil resources; ADPF = Abiotic depletion potential for fossil resources; WDP = Water (user) deprivation potential)

RESULTS OF THE LCA - INDICATORS TO DESCRIBE RESOURCE USE according to EN 15804+A2: 1 pce CS8800iAW 11 O-T

Parameter	Unit	A1-A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
PERE	MJ	4.97E+03	2.14E+01	1.43E+01	0	0	8.59E-01	0	0	1E+05	0	0	8.65E-01	2.89E+01	1.36E+01	-4.59E+02
PERM	MJ	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PERT	MJ	4.97E+03	2.14E+01	1.43E+01	0	0	8.59E-01	0	0	1E+05	0	0	8.65E-01	2.89E+01	1.36E+01	-4.59E+02
PENRE	MJ	2.29E+04	1.38E+03	3.09E+02	0	0	1.2E+01	0	0	5.06E+05	0	0	5.55E+01	2.42E+02	3.34E+02	-3.53E+03
PENRM	MJ	2.99E+00	4.09E-02	1.26E-02	0	0	4E-04	0	0	2.94E+00	0	0	1.64E-03	9E-03	1.04E-02	-3.59E-02
PENRT	MJ	2.29E+04	1.38E+03	3.09E+02	0	0	1.2E+01	0	0	5.06E+05	0	0	5.55E+01	2.42E+02	3.34E+02	-3.53E+03
SM	kg	7.15E+01	0	3.22E+00	0	0	3.9E-04	0	0	0	0	0	0	0	0	0
RSF	MJ	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NRSF	MJ	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
FW	m^3	2.46E+01	1.96E-01	1.37E-01	0	0	1.36E-02	0	0	3.62E+02	0	0	7.91E-03	1.19E-01	2.17E-01	-2.52E+00

PERE = Use of renewable primary energy excluding renewable primary energy resources used as raw materials; PERM = Use of renewable primary energy resources used as raw materials; PERT = Total use of renewable primary energy resources; PENRE = Use of non-renewable primary energy excluding non-renewable primary energy resources used as raw materials; PENRM = Use of non-renewable primary energy resources used as raw

materials; PENRT = Total use of non-renewable primary energy resources; SM = Use of secondary material; RSF = Use of renewable secondary fuels; NRSF = Use of non-renewable secondary fuels; FW = Use of net fresh water

RESULTS OF THE LCA – WASTE CATEGORIES AND OUTPUT FLOWS according to EN 15804+A2:
1 pce CS8800iAW 11 O-T

Parameter	Unit	A1-A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
HWD	kg	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NHWD	kg	0	0	8.81E+00	0	0	6.42E-04	0	0	0	0	0	0	0	1.11E+02	0
RWD	kg	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CRU	kg	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MFR	kg	1.88E+01	0	1.74E+01	0	0	1.01E-03	0	0	0	0	0	0	1.39E+02	0	0
MER	kg	2.28E+01	0	1.01E+01	0	0	2.06E-05	0	0	0	0	0	0	2.3E+01	0	0
EEE	MJ	6.7E+01	0	2.66E+01	0	0	0	0	0	0	0	0	0	1.03E+02	0	0
EET	MJ	1.56E+02	0	6.21E+01	0	0	0	0	0	0	0	0	0	2.41E+02	0	0

HWD = Hazardous waste disposed; NHWD = Non-hazardous waste disposed; RWD = Radioactive waste disposed; CRU = Components for re-use; MFR = Materials for recycling; MER = Materials for energy recovery; EEE = Exported electrical energy; EET = Exported thermal energy

RESULTS OF THE LCA – additional impact categories according to EN 15804+A2-optional:
1 pce CS8800iAW 11 O-T

Parameter	Unit	A1-A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
PM	Disease incidence	1.22E-04	5.66E-06	1.12E-06	0	0	4.84E-08	0	0	3.9E-04	0	0	2.29E-07	1.16E-06	1E-06	-1.69E-05
IR	kBq U235 eq	1.13E+02	1.84E+00	1.07E+00	0	0	5.34E-02	0	0	1.28E+04	0	0	7.44E-02	1.91E+00	1.15E+00	-4.59E +00
ETP-fw	CTUe	2.09E+05	1.39E+03	3.52E+02	0	0	3.58E+01	0	0	3.96E+05	0	0	5.6E+01	9.86E+02	2.48E+03	-1.75E +04
HTP-c	CTUh	1.01E-05	4.63E-08	1.68E-08	0	0	2.68E-09	0	0	1.13E-05	0	0	1.86E-09	2.43E-08	4.06E-08	9.8E-07
HTP-nc	CTUh	3.13E-04	1.13E-06	2.69E-07	0	0	4.03E-08	0	0	4.26E-04	0	0	4.55E-08	1.13E-06	8.13E-07	-2.02E-05
SQP	SQP	1.82E+04	8.19E+02	6.01E+01	0	0	4.69E+00	0	0	9.22E+04	0	0	3.32E+01	2.68E+02	6.88E+01	-9.68E +02

PM = Potential incidence of disease due to PM emissions; IR = Potential Human exposure efficiency relative to U235; ETP-fw = Potential comparative Toxic Unit for ecosystems; HTP-c = Potential comparative Toxic Unit for humans (cancerogenic); HTP-nc = Potential comparative Toxic Unit for humans (not cancerogenic); SQP = Potential soil quality index


Disclaimer 1 – for the indicator “Potential Human exposure efficiency relative to U235”. This impact category deals mainly with the eventual impact of low-dose ionizing radiation on human health of the nuclear fuel cycle. It does not consider effects due to possible nuclear accidents, occupational exposure or radioactive waste disposal in underground facilities. Potential ionizing radiation from the soil, radon and from some construction materials is also not measured by this indicator.

Disclaimer 2 – for the indicators “abiotic depletion potential for non-fossil resources”, “abiotic depletion potential for fossil resources”, “water (user) deprivation potential, deprivation-weighted water consumption”, “potential comparative toxic unit for ecosystems”, “potential comparative toxic unit for humans – cancerogenic”, “Potential comparative toxic unit for humans - not cancerogenic”, “potential soil quality index”. The results of this environmental impact indicator shall be used with care as the uncertainties on these results are high as there is limited experience with the indicator.

6. LCA: Interpretation

The operational energy use (B6) contributes >80 % to all impact indicators. To allow for a detailed interpretation, the energy use was thus excluded.
Over 80 % of the heat pump units' overall impacts are related to A1-A3 Raw material supply, except for GWP-biogenic, where 68 % of the impacts are attributed to C4, disposal, specifically the landfilling of other materials.
For A1-A3 Raw Material Sourcing, the LCA identifies the ODUs core components (Metals, Complex, Electronic) as the primary environmental burden (>80 % of impacts for most categories).
In general, copper and steel are the most significant material drivers, along with contributions from the evaporator and inverter, specifically. The influence resulting from metals, complex and electronic components combined are below 80 % for SQP and ODP with impacts stemming from packaging materials (sawn wood, MDF, paper) and polyester.
Except for HTP-c, whose burdens are attributed to the steel recycling process, Module D generates environmental credits across all LCIA indicators, stemming from the substitution of market (virgin) materials with recycled metals (aluminium, copper, brass, and steel).

In terms of waste categories and output flows, C3 (~41 - 79 %), followed by A1-A3 (11 - 41 %), contains the highest proportion of MFR (due to the high share of metals, namely steel, aluminium and copper), MER, EEE and EET.



7. Requisite evidence

The technical documentation related to the heat pump unit is available here: www.bosch-homecomfort.com.
The product family contains the refrigerant R290. According to *ISO 817*, propane is classified as class A (lower toxicity) and 3 (higher flammability). The operation of the heat pump unit does not generate waste gas.

8. References

Standards

ECHA Candidate List
European Chemicals Agency, Candidate List of substances of very high concern for Autorisation published in accordance with Article 59(10) of the REACH Regulation.

ecoinvent 3.9.1 database
Wernet, G., Bauer, C., Steubing, B., Reinhard, J., Moreno-Ruiz, E., and Weidema, B., 2016. The ecoinvent database version 3 (part I): overview and methodology. The International Journal of Life Cycle Assessment, [online] 21(9), pp.1218–1230.

EMC 2014/30/EU
Directive 2014/30/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to electromagnetic compatibility (recast) Text with EEA relevance.

EN 12102-1:2022
EN 12102-1:2022, Air conditioners, liquid chilling packages, heat pumps, process chillers and dehumidifiers with electrically driven compressors. Determination of the sound power level. Air conditioners, liquid chilling packages, heat pumps for space heating and cooling, dehumidifiers and process.

EN 14511:2018
EN 14511:2018, Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 1: Terms and definitions.

EN 14825:2022
EN 14825:2022, Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling, commercial and process cooling - Testing and rating at part load conditions and calculation of seasonal performance; German version EN 14825:2022.

EN 15804
EN 15804:2012+A1 2013, Sustainability of construction works — Environmental Product Declarations — Core rules for the product category of construction products.

EN 378-2:2018-04
Refrigerating systems and heat pumps - Safety and environmental requirements - Part 2: Design, construction, testing, marking and documentation.

EC 61000-3-2:2018+A1+A2
IEC 61000-3-2:2018/AMD2:2024 - Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)

EN 61000-3-3:2013+A1:2019+A2:2021+A2:2021+AC:2022
EN 61000-3-3:2013, Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection (IEC 61000-3-3:2013).

EN 62233:2008+AC:2008
EN 62233:2008+AC:2008, Measurement methods for electromagnetic fields of household appliances and similar apparatus with regard to human exposure.

EN IEC 55014-1:2021
EN IEC 55014-1:2021, Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission.

EN IEC 55014-2:2021-04-01
EN IEC 55014-2:2021-04-01 Electromagnetic compatibility. Requirements for household appliances, electric tools and similar apparatus. Immunity. Product family standard.

EN IEC 61000-3-11:2019
EN IEC 61000-3-11:2019, Electromagnetic compatibility (EMC) Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current <= 75 A and subject to conditional connection.

EN IEC 63000:2018
DIN EN IEC 63000:2019-05, Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances(IEC 63000:2016); German version EN IEC 63000:2018.

ErP 2009/125/EC + (EU) 813/2013
Commission Regulation (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters Text with EEA relevance.

2012/19/EU
Directive 2012/19/EU on waste electrical and electronic equipment' 2022, URL: https://eplca.jrc.ec.europa.eu/LCDN/developerEF.html. Accessed: 06.05.2022.

IEC 60335-1:2020+A1
IEC 60335-1:2020+A1, Household and similar electrical appliances - Safety - Part 1:General requirements.

IEC 60335-2-40:2024
Household and Similar Electrical Appliances - Safety - Part 2-40: Particular Requirements for Electrical Heat Pumps, Air-Conditioners and Dehumidifiers.

ISO 14001:2015
ISO 14001:2015, Environmental Management System.

ISO 14025
EN ISO 14025:2011, Environmental labels and declarations — Type III environmental declarations — Principles and procedures.

ISO 45001:2018
ISO 45001:2018, Occupational Health and Safety Management.

ISO 817:2024-11
ISO 817:2024-11, Refrigerants - Designation and safety classification Refrigerants - Designation and safety classification.

LVD2014/35/EU
Directive 2014/35/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits (recast) Text with EEA relevance.

PED 2014/68/EU
Directive 2014/68/EU of the European Parliament and of the Council of
15 May 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of pressure equipment (recast) Text with EEA relevance.

REACH Regulation (EC 1907/2006)
Regulation (EC) No 1907/2006 of the European Parliament and of the Council of 18 December 2006 concerning the Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH), establishing a European Chemicals Agency, amending Directive 1999/45/EC and repealing Council Regulation (EEC) No 793/93 and Commission Regulation (EC) No 1488/94 as well as Council Directive 76/769/EEC and Commission Directives 91/155/EEC, 93/67/EEC, 93/105/EC and 2000/21/EC.

RoHS 2011/65/EU + (EU)2015/863
RoHS 2011/65/EU + (EU)2015/863, Delegated Directive (EU) 2015/863 of 31 March 2015 amending Annex II to Directive 2011/65/EU of the European Parliament and of the Council as regards the list of restricted substances (Text with EEA relevance).

Guidelines

European Commission 2022
European Commission. European Platform on LCA/EPLCA. Developer Environmental Footprint (EF) (Annex C).

PCR EPDItaly019
EPDItaly Core PCR - HVAC Home Appliances, GPI version 5.0, 2021.

PEP ecopassport PSR,2021
PEP ecopassport Program PCR. Product Category Rules for Electrical, Electronic and HVAC-R Products, P.E.P. Association, 2021. **Applied PCRs**
PCR IBU Part A
PCR Version 1.4, Part A Institut Bauen und Umwelt e.V., Berlin (pub.): Product Category Rules for Building-Related Products and services, Part A: Calculation Rules for the Life CycleAssessment and Requirements on the Project Report, according to 15804+A2:2019.

PCR IBU Part B
PCR Version 2, Guidance-Texts for Building-Related Products and Services from the range of Environmental Product Declarations of Institute Construction and Environment e.V. (IBU) Part B: Requirements on the EPD for HVAC Appliances (2023).

Publisher

Institut Bauen und Umwelt e.V.
Hegelplatz 1
10117 Berlin
Germany

+49 (0)30 3087748- 0
info@ibu-epd.com
www.ibu-epd.com

Programme holder

Institut Bauen und Umwelt e.V.
Hegelplatz 1
10117 Berlin
Germany

+49 (0)30 3087748- 0
info@ibu-epd.com
www.ibu-epd.com

Author of the Life Cycle Assessment

Bosch Thermotechnik GmbH
Sophienstraße 30-32
35576 Wetzlar
Germany

+49 152 28037119
Pia.Szichta@de.Bosch.com
https://www.bosch-homecomfortgroup.com/de/startseite.html

Owner of the Declaration

Bosch Thermotechnik GmbH
Sophienstraße 30-32
35576 Wetzlar
Germany

+49 152 28037119
Pia.Szichta@de.Bosch.com
https://www.bosch-homecomfortgroup.com/de/startseite.html