

C € 0085



CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085DL0480

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Junkersstrasse 20, D-73249 Wernau
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	gas wall hung condensing boiler
Model <i>Modell</i>	Bosch Condens 7000 WP GC7000WP...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, BY, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MD, NL, NO, PT, RO, RS, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	type testing: 21-00944-AB02-458 from 03.11.2021 (EBI) type testing: 20-00283-458 from 14.01.2021 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 22.04.2031 / 21-0682-GER
Ablaufdatum / AZ

26.11.2021 Pz B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK, EE, FI, LV, NO, SE	
I3P	37 mbar	BE	
II2E3P	20, 50 mbar	LU	
II2EK3P	20/25, 30 mbar	NL	
II2ELL3B/P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	RO	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, LT, PT, SI, SK, TR	
II2H3P	20, 50 mbar	AT, CH	
II2HS3P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
... GC7000WP 50	nominal heat output: 13,0...46,6 kW heat input (Hi): 13,3...47,5 kW	
... GC7000WP 65; ... GC7000WP 70 (H23)	nominal heat output: 13,0...62,6 kW heat input (Hi): 13,3...64,3 kW	
... GC7000WP 85	nominal heat output: 18,9...80,0 kW heat input (Hi): 19,3...82,0 kW	
... GC7000WP 100 (H23)	nominal heat output: 18,9...94,5 kW heat input (Hi): 19,3...96,5 kW	
... GC7000WP 125	nominal heat output: 24,1...118,1 kW heat input (Hi): 24,5...119,3 kW	
... GC7000WP 125	sanitary water heat input (Hi): 24,1...117,0 kW	For NL market
... GC7000WP 150	nominal heat output: 24,5...118,2 kW nominal heat output: 24,1...141,7 kW heat input (Hi): 24,5...143,0 kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

flue types B23P, B53P, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x) and C93(x): according to installation manual.

Additionally tested appliance categories, supply pressures and countries of destination:

BG; I2H (20 mbar)

BY; UA; II2H3P (20; 37 mbar)

MD; II2H3P (20; 30 mbar)

RS; RU; I2H (20 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

The recognition of the CE mark in the United Kingdom is currently limited to January 1st, 2023.

