

Robert Bosch GmbH
Postfach 13 09
73243 Wernau
Besucher:
Junkersstraße 20-24
73249 Wernau
Telefon +49 7153 306-0
Telefax +49 7153 306-2300
www.bosch.com

22. Mai 2024

We,
Bosch Thermotechnik GmbH,
Hereby declare that the below listed air-to-water heat pumps reach SCOP
values provided in the table below. The SCOP values were calculated based
on EN 14825:2018 and in combination with the CS5800iAW 12 E indoor unit.

Model name	Ordering number	SCOP	Climate
AW 4 OR-S	8738215701	4.58	Average Climate, Low Temperature (35°C)
AW 5 OR-S	8738215702	4.57	
AW 7 OR-S	8738215703	4.58	
AW 10 OR-T	8738215704	4.77	
AW 12 OR-T	8738215705	4.66	

Head of Engineering
HC-ES/TE

Head of Quality
HC/QMM-ES

Thomas Finke

Thomas Schmeichel